



page 1

# JALOUSIE ACTUATOR JAS-04.16

#### **BASIC INFORMATION**

The jalousie actuator is designed to control motorized curtains, jalousie, roller shutters and similar devices powered by AC. Each output has a bistable relay, designed for high inrush currents, and can be controlled manually.

- 4 independent channels for a maximum capacitive load of  $140\mu F$
- Ability to connect outputs to different phases
- Manual control of outputs using front panel buttons
- LED indication of output status
- Extendet logic and scenario functions for each output
- · The choice of operation mode curtains / jalousie
- Saving settings during a KNX power failure
- Power supply via KNX bus
- DIN rail 35 mm mounting



 1. Outputs
 2. Output status indicator LED
 3. Output control button

 4. Programming button
 5. Programming LED
 6. KNX connector

Module Electronic LLC module-electronic.ru, info@module-electronic.ru phone: +7-495-150-27-25

# Module<sup>®</sup>



page 2


## SPECIFICATIONS


Device model	JAS-04.16
Outputs (control channels)	
Number of outputs	4
Output type / Disconnection type	Potential-free outputs-bistable relay with tungsten pre-make contact / Micro-disconnection
Rated current per output	16A/230V AC
Capacitive load	140µF
Maximum switching voltage	400V AC
Maximum load (resistive / inductive)	4000W / 1500W
Maximum inrush current	165A/20ms 800A/200μs
Maximum relay response time	10ms
Cross-section of the connected wire to the screw terminals	0,5-4mm²
Mechanical lifetime of the relay (cycles, minimum)	3.000.000
KNX interface	
Specification	TP-256
Available application software	ETS 5
KNX connector	4-wire EIB connector (PUSH WIRE spring clips) for standard cable TP1 0,8мм Ø
Power supply	via KNX bus
Consumption on the KNX bus (29V DC)	< 5mA < 150mW
Operation temperature	0°C + 45°C
Operation humidity	5 95% (no condensation)
Degree of protection	IP 20, clean environment
Mounting type	DIN rail 35mm
Dimensions	71,3 x 90,5 x 62mm (4TE)
Weight	260g


page 3


### INSTALLATION

Attaching to DIN rail













Removing from DIN rail










#### WIRING DIAGRAMS





page 4

#### SAFETY INSTRUCTIONS



**ATTENTION!** Installation and connection of the device to the mains must only be carried out by qualified personnel! There is a risk of electric shock! Be sure to turn off the power before installing or removing the device! Even when the device is turned off, the output terminals can be live! Do not connect to the outputs a load that exceeds the recommended values! The design of the device meets the requirements of electrical safety according to GOST 12.2.007.0-75.

#### SETTING INSTRUCTIONS

The device is set up in accordance with the instruction manual. (The full manual and application program can be downloaded at https://module-electronic.ru/documents or by scanning the QR code at the bottom of the document).

#### TRANSPORTATION, STORAGE AND DISPOSAL

The conditions for the transportation of devices must comply with conditions 5 of GOST 15150-69. Storage of devices in packaging at the warehouses of the manufacturer and consumer must comply with storage conditions 1 in accordance with GOST 15150-69. After transportation or storage at low temperatures, it is necessary to withstand the device at room temperature for at least 2 hours before turning it on. Do not dispose of the device with household waste.

#### WARRANTY

Warranty period - 12 months from the date of sale to the consumer. The manufacturer is not liable and does not indemnify for damage caused by the fault of the consumer in case of non-compliance with the conditions of transportation, storage, installation and operation, as well as in case of violation of the seal when trying to repair the device yourself.

All the necessary information on the warranty can be obtained by the consumer by calling Module Electronics or on the website: www.module-electronic.ru.

Serial number	
Date of sale	seller's stamp
Seller Signature	
Name, address of the trading organization	

User Manual



